



# Certificate of Compliance

**Certificate Number:** LR 107857-2

**Revision:**

**Date Issued:** August 7, 1997

**Issued to:** Delta Controls Corp.  
585 Fortson Street  
Shreveport, LA 71107 U.S.A.  
Attention: Mr. Ted Keys

*The products listed below are eligible to bear the CSA Mark*

**Issued by:** Eric Chow  
Toronto, ON Canada

**Signature:** 

## PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations  
CLASS 4418 82 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations - CERTIFIED TO U.S. STANDARDS

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III; Encl 4X:

- Instrument Housing, Part Nos 11-343, 11-511, 11-347, 11-512, with or without window, threaded for a maximum of 4 rigid metal conduit connections, conduit sizes 0.5 to 0.75 in max.

CLASS 4411 01 - OUTLET BOXES AND FITTINGS - Boxes  
CLASS 4411 81 - OUTLET BOXES AND FITTINGS - Boxes - CERTIFIED TO U.S. STANDARDS

- Instrument Housing, Part Nos 11-437, 11-686, 11-625, 11-040, with or without window, maximum of 4 conduit entries, up to 0.75 in maximum. Type 4X.



**Revision:**

---

**APPLICABLE STANDARDS**

- |                            |  |
|----------------------------|--|
| CAN/CSA-C22.2 No. 94-M91   | - Special Purpose Enclosures   |
| CSA Std C22.2 No. 25-1966  | - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations    |
| CSA Std C22.2 No. 30-M1986 | - Explosion Proof Enclosures for Use in Class I Hazardous Locations        |
| UL Std No.508              | - Industrial Control Equipment   |
| UL Std No 886              | - Industrial Control Equipment for Use in Hazardous (Classified) Locations |
| UL Std No.698              | - Industrial Control Equipment for Use in Hazardous (Classified) Locations |

**MARKINGS**

- Company Name
- Model number
- Serial number
- Hazardous Location designation
- Special purpose enclosure designation, "Encl 4"
- CSA Monogram with NRTL/C indicator
- Caution: Open circuit before removing cover or keep cover tight while circuits are alive
- Seal shall be installed within 18 in of the enclosure.



## *Supplement to Certificate of Compliance*

**Certificate Number:** LR 107857-2

**Issued to:** Delta Controls Corp.  
585 Fortson Street  
Shreveport, LA 71107 U.S.A.  
Mr. Ted Keys

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

**Issued By:** Eric Chow  
Toronto, ON Canada

**Signature** *Eric Chow*

### **Product Certification History**

---

<b>Revision</b>	<b>Date</b>	<b>Description</b>
LR 107857-2	Aug 7, 1997	Original Certification